

Number	20-002482-PR01 (NW-A01-02-en-01)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	Double tilt and turn casement door with central opening meeting stile
Designation	System: S77 Aluwood Shipping name: S77 Aluwood
Details	Manufacturer ALUMIL S.A., - Kilkis; Material Aluminium system with thermal break with internal wood panelling; Type of opening Turn / tilt and turn; Opening direction Active casement DIN right (opening) to the inside, Inactive casement DIN left (opening) to the inside; Overall dimensions (W x H) 1500 mm x 2200 mm
Special features	Material compatibility must be taken into account. Material durability must be taken into account.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C3/B3

Watertightness according to EN 12208:1999-11



Class: E1050

ift Rosenheim

02.07.2020



Michael Breckl-Stock
Deputy Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions (e.g. DIN EN)

Test report: 20-002482-PR01 PB-A01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 294-F0F38